



**NOTES:**

1. **STONE SIZE:** 75-125 mm (3-5") OPEN GRADED ROCK.
2. **LENGTH:** AS EFFECTIVE BUT NOT LESS THAN 15 m (50').
3. **THICKNESS:** NOT LESS THAN 200 mm (8").
4. **WIDTH:** NOT LESS THAN FULL WIDTH OF ALL POINTS OF INGRESS/EGRESS.
5. **WASHING:** WHEN NECESSARY, VEHICLE WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC ROADWAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH CRUSHED STONE AND DRAINS INTO AN APPROVED TRAP OR SEDIMENT BASIN. ALL SEDIMENT SHALL BE PREVENTED FROM ENTERING ANY STORM DRAIN, DITCH OR WATERCOURSE USING APPROVED METHODS.
6. **MAINTENANCE:** THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION THAT WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC ROADWAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND, AS WELL AS REPAIR AND CLEAN OUT OF ANY MEASURE DEVICES USED TO TRAP SEDIMENT. ALL SEDIMENTS THAT IS SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC ROADWAY MUST BE REMOVED IMMEDIATELY.
7. **DRAINAGE:** ENTRANCE MUST BE PROPERLY GRADED OR INCORPORATE A DRAINAGE SWALE TO PREVENT RUNOFF FROM LEAVING THE CONSTRUCTION SITE.

**CITY OF AUSTIN**

WATERSHED PROTECTION DEPARTMENT

**STABILIZED CONSTRUCTION ENTRANCE**

RECORD COPY SIGNED  
BY J. PATRICK MURPHY

5/23/00

ADOPTED

THE ARCHITECT/ENGINEER ASSUMES  
RESPONSIBILITY FOR APPROPRIATE USE  
OF THIS STANDARD.

STANDARD NO.

**641S-1**